BAM
Federal Institute for Materials Research and Testing
D-12200 Berlin
Germany
Telephone: ++49-30-81 04-0
Telefax: ++49-30-8 11 20 29
E-mail: sales.crm@bam.de
Internet: www.bam.de/crm

Tank Bottom Valve (Fire Safe)

Certificate N°: BAM/ZBA/010/03

1st issue

Hereby it is certified by the BAM Certification that the abovementioned tank bottom valve with pneumatic drive with the designation

BA 10
Nominal width: DN 150, DN 200, DN 250 and 6", 8", 10", 12"
Nominal pressure: PN 16, PN 25 and Class 150, Class 300

of the manufacturer

RITAG Armaturenwerk GmbH & Co. KG
Industriestraße 7 – 9
27711 Osterholz-Scharmbeck

meets the requirements set out in BS 6755, Part 2 of 1987, of the British Standard Institutes (Testing of valves, Part 2. Specification for fire type-testing requirements).

Based on DIN EN 45 011:1998, the certification includes a prototype testing with product assurance including first inspection of the manufacturing unit (BAM Certification System II a).

For using the BAM Certificate as well as the Certification "BAM Geprüftes Produkt"/ "BAM Certified and under surveillance" for manufactured products according to the certified prototype the manufacturer shall provide to the client a declaration of conformity.

The Certificate has a validity of 5 years starting with the date of issue.

The BAM Test Report Az.: II-4819/2002 dated 14.05.2003 is a basis of conformity assessment for and part of this Certificate.

On behalf of Bundesanstalt für Materialforschung und -prüfung (BAM)

Unter den Eichen 87,12205 Berlin,

2003-05-15

Dr. R. Schmidt
BAM Certification Body

BUNDESANSTALT FÜR MATERIALFORSCHUNG UND -PRÜFUNG (BAM) 51

Dr. B. Schalau
Assessor

CERTIFICATE

Distribution list: 1st Manufacturer 2nd BAM Certification Body 3rd Assessor

The BAM Certification Body has been accredited by the DAP Deutsches Akkreditierungssystem Prüfwesen GmbH according to DIN EN 45011. The accreditation applies only to the fields of certification specified in the Certificate (DAP-ZE-02.614.15).

Certificates may be published only in full wording and without any additions. For changed reproduction and excerpts a revocable permission in writing has to be obtained from BAM. The German Certificate is authoritative. Court of jurisdiction is Berlin.